






OPTION 1



Anmerkung / REMARKS	
b	SPACE REQUIRED FOR MEASURING TORSIONAL VIBRATIONS, AND/OR FOR REMOVAL OF THE VIBRATION DAMPER AND/OR LUBOIL PUMP
e	SPACE REQUIRED FOR REMOVAL OF PISTON AND CYLINDER LINER REDUCED REMOVAL HEIGHT PISTON AND LINER 2300mm
k	SPACE REQUIRED FOR TERMINAL SET
o	SPACE REQUIRED FOR TURBOCHARGER SHAFT
p	SPACE REQUIRED FOR CHARGE AIR COOLER REMOVING

CATERPILLAR MOTOREN GmbH & Co. KG RESERVES THE RIGHT TO
MODIFY AND AMEND DATA AT ANY TIME. ANY LIABILITY FOR
ACCURACY OF INFORMATION PROVIDED IS EXCLUDED.
WE WILL SUPPLY FURTHER BINDING DATA IN CONNECTION WITH A CORRESPONDING ORDER.

ALL RIGHTS RESERVED. NO PART OF THIS PUBLICATION
MAY BE REPRODUCED OR COPIED IN ANY FORM,
WITHOUT PRIOR WRITTEN PERMISSION OF CATERPILLAR MOTOREN GmbH & Co. KG.

CATERPILLAR		Model 6M32C_GENSET 1.11
Drawing 6M32C_GENSET 1.5		
Überflächen Surfaces ISO 1802	Allgemeinskizzen General Sketches ISO 2768 - mK	Drawing Control W 882
Benennung Name Aggregat - Einbauzeichnung DIESEL GEN SET INSTALLATION DRAW ING		Prozess Scale 1:25
Arzt-Stand Charge Level —	Freigabe-Nr. Release No. —	Zeichnungs-Nr. Drawing No. 6M32C GENSET
		Blatt Sheet 1 von 3